


SLIDING DOOR, THUS  
LANDING IS NOT REQUIRED

EXTERIOR  
PATIO


R.O. 6'-0" x 6'-8"  
FWG606BL



SWINGING GLASS DOOR  
SO LANDING IS REQUIRED  
BY THE WAY THE CODE  
IS CURRENTLY WRITTEN

EXTERIOR  
PATIO

R.O. 6'-0" x 6'-11"  
FWH60611ASR



SP8321.04(4)(c)c.

(c) *Doors at landings.* 1. Except as provided in subd. 1. a. to c., level landings shall be provided on each side of any door located at the top or base of a stairs, regardless of the direction of swing. In the following exceptions, stairways to attached garages, carports or porches are considered interior stairs:

a. A landing is not required between the door and the top of interior stairs if the door does not swing over the stairs.

b. A landing is not required between the door and the top of an interior stairs of 1 or 2 risers regardless of the direction of swing.

c. A landing is not required between a sliding glass door and the top of an exterior stairway of 3 or fewer risers.



400 SERIES  
FRENCHWOOD GLIDING  
PATIO DOOR

- Traditional French door styling
- Convenient gliding, space-saving design
- Energy efficient
- Solid wood door
- Quality construction with mortise-and-tenon dowel joints
- Dual ball-bearing rollers



400 SERIES  
FRENCHWOOD HINGED  
PATIO DOOR

- Traditional French door styling
- Energy efficient
- Solid wood door
- Quality construction with mortise-and-tenon dowel joints
- Multipoint locking system that seals the doors tight at the top, center and bottom

AS YOU WILL SEE, USING ANDERSEN SLIDING DOORS AND SWINGING DOORS AS AN EXAMPLE (PICTURES ARE RIGHT FROM THEIR WEBSITE), THE UNOBSTRUCTED GLASS HEIGHT OF BOTH DOORS IS 66" (TAKEN FROM THE ANDERSEN PRODUCT GUIDE) THUS GIVING YOU THE SAME VIEW TO SEE IF THERE ARE STEPS OUTSIDE THE DOOR OR NOT. THEREFORE, IT IS MY REQUEST THAT THE WORD "SLIDING" BE REMOVED FROM THE CODE AND THEREBY READING "c. A landing is not required between a glass door and the top of an exterior stairway of 3 or fewer risers."