



## Air Admittance Valves

**55. SPS 382.31(3) - 11/19/97**

**Are air admittance valves approved in Wisconsin?** The approval of specific air admittance valves is included among the product evaluations.

**151. SPS 384.10(1) - 10/4/05**

**May air admittance valves be installed to serve chemical waste systems?** No. If chemical resistant piping is installed to serve a fixture, an air admittance valve is not permitted as a vent termination.